

To whom it may concern,

Laminex New Zealand certifies that the attached certificate for VOC emissions (ASTM D5116 "Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products") applies to Laminex Acrylic Panel.

As of October 2019, Laminex Acrylic Panel is the updated name of the product previously known as Melteca Acrylic Soft Touch

For further information, contact sustainability@laminex.co.nz

Emission Test Certificate

Wednesday, 04th July 2018

Supplier: The Laminex Group Technology Centre (21 Trewin Street, Wendouree, VIC, 3355)

Sample Description: Melteca Acrylic Soft Touch

Date Tested: June 2018 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116-17 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Materials/Products”.

Emission Data (7 days exposure):

<p align="center">Green Building Council of Australia Green Star Design & As Built v1.1 13.1.2B & 13.2 Green Star Interiors V1.1 - 12.1.2B</p>	<p align="center">Melteca Acrylic Soft Touch</p>
<p align="center">Total Volatile Organic Compound Emission Rate limit <0.5 mg/m²/hr</p>	<p align="center">Total Volatile Organic Compound Emission Rate: 0.026 mg/m²/hr</p>



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Nick Joy
BSc(Hons)
Consultant



Tuan Duong
B Eng. (Chem.)
Consultant

CV180618A