

Emission Test Certificate

Friday 16th April 2021

Supplier: The Laminex Group Technology Centre (22 Trewin Street, Wendouree, VIC, 3355, Australia)

Sample Description: Decorated board - 27489 Melteca F2S PBD MR 18mm

Date Tested: March 2021 (Tested by FORAY Laboratories – NATA Accreditation 1231)


Test Method: ASTM D5116-2017 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data (24 hrs):

<p align="center">Green Building Council of Australia Green Star Design & As Built V1.3 - 13.1.2B & 13.2 Green Star Interiors V1.3 - 12.1.2B</p>	<p align="center">Decorated board 27489 Melteca F2S PBD MR</p>
<p>Total Volatile Organic Compound Emission Rate Limit: ≤0.500 mg/m²/hr</p>	<p>Total Volatile Organic Compound Emission Rate: 0.101 mg/m²/hr</p>



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Travis Hale
BSc (Biotechnology)
Consultant



Dr. Tuan Duong
PhD, B.Eng. (Chemical)
Senior Consultant

V2103057