



NATA Accredited Laboratory

Accreditation No: 15305

Accredited for compliance with  
ISO/IEC 17025 - Testing

**Laminex**<sup>®</sup>

a division of Laminex Group Pty Ltd ABN 98 004 093 092

## The Laminex Group Technology Centre

Postal Address: PO BOX 720, Wendouree, Vic 3355

Address: 22 Trewin St, Wendouree, Vic 3355

Telephone: (03) 5337 3613

Fax: (03) 5337 3647

**Test Report No.**  
**1924173**

**Date of Issue**  
**28/05/2019**

**Client:**  
**Laminex New Zealand**  
1 O'Rorke Road  
Penrose  
Auckland  
New Zealand

This test report shall not be reproduced, except in full,  
without written approval from The Laminex Group Technology Centre

The material contained in this report is confidential to the entity identified as 'Client' above.


As the sample(s) have been provided by the client, the results contained in this report apply only to the sample(s) as received.

Test Report No. 1924173

Date of Issue: 28/05/2019

Laminex Sample Reference No.	24173
Client Sample Reference No.	<b>Strandfloor H3.1</b>
Product Description: (Supplied by client)	20mm Strandfloor H3.1
Surface Treatment	None (raw)
Receive Date:	15/04/2019
Condition:	Good.
<b>Specification Standard</b>	<b>AS/NZS 1859.1:2017</b>

Sample photographs



Test	Method	Unit	Result		Product limit		Compliance
			Mean	Std Dev	Limit Value	Standard Clause	
Formaldehyde Emission	AS/NZS 4266.1: 2017 Section 17	mg/L	<b>0.06</b>	0.00	<b>Maximum 0.3 (SE0)</b>	Clause 6.3 Table 1	<b>PASS SE0</b>

**Formaldehyde Emission Class: Super E0**

Comments

As agreed to by the client, compliance to product limits is based solely on the reported test result(s) and no uncertainty of measurement shall be taken into account.

Approved Signatory:  
Laboratory Manager (J. Smolenaers)...